



FMEDA

Awards this

Certificate of Analysis

Failure Modes, Effects & Diagnostic Analysis

to

SMAR
First in Fieldbus

for their

Series LD301

December 20, 2002



λ^H	=	$6.5 * 10^{-9}$	failures per hour
λ^L	=	$222 * 10^{-9}$	failures per hour
λ^{DU}	=	$160 * 10^{-9}$	failures per hour
SFF	=	65.7%	

John C. Grebe Jr., Product Analyst

Dr. William M. Goble, P.E., CFSE